



Checklist for gas cylinders

- All cylinders are secured upright and with their valve caps in place when not in use
- Cylinders are stored away from traffic and electrical panels
- Stored oxygen cylinders are separated from acetylene cylinders and combustible materials (e.g., oil, gasoline, propane) by a minimum of 20 feet or by a non-combustible barrier at least 5 feet high
Exception: Oxygen cylinders on an oxyacetylene cart with gauges attached
- Empty cylinders are marked
- Damaged cylinders are marked

Problems?

- No
- Yes

Date of inspection: _____